

**ATTACHMENT 3
PLATFORM ELLY
NON-CONTACT COOLING WATER CHLORINE RESULTS
July 1, 2021 through September 30, 2021**

<u>Discharge</u>	<u>Measurement Frequency</u>	<u>Average Monthly Limit ¹ Post Dilution</u> (mg/l)	<u>Maximum Daily Limit ¹ Post Dilution</u> (mg/l)		<u>Result Post Dilution</u> (mg/l)		<u>End-of-Pipe Concentration</u> (mg/l) EPA Method 330.5	<u>EPA Plumes Dilution</u>
009 Non-contact Cooling Water 7/29/2021	Once/Quarter	0.00585	0.0102	<	0.0002	<	0.05	277:1

¹ Limits are post-dilution as listed in Appendix C of the Permit.